



**Date: 17/10/2023**

**CORRIGENDUM /CLARIFICATION**

1. It is notified to all concerned parties that with reference to our GeM **Tender No. GEM/2023/B/4046186** dated: 05 Oct 23 the following changes/clarifications are being made with respect to the Tender: -

Description	Clarification
Annexure A – Senate Hall	Chemical Anchoring is not required, the Chair will have to be fixed by Anchoring.
Annexure C – Director’s Conference Room Meeting Table -	The table will have 2 Nos Flip Box – Each Box will consist of 1 USB, 1 HDMI, 3 Power Sockets, 1 Network port. (Universal type); Brands like- legrand, northwest, Wipro and MK will only be accepted
For <b>Clusters &amp; Workstations</b> specified in all the Annexures	<p>Every workstation will have:</p> <ol style="list-style-type: none"> <li>1) a Wire Manager Hole with cap</li> <li>2) 4 sockets and 2 switches (below the table). Brands like- legrand, northwest, Wipro and MK will only be accepted</li> <li>3) Raceway for LAN cabling and Telephone connection for all workstations</li> <li>4) Raceway for electrical wiring</li> </ol> 
For DR, AR cabins and wherever executive office tables mentioned in all annexures	<p>Provision for electrical and cabling - flip box model</p> <ol style="list-style-type: none"> <li>1) Raceway - Below the table along with 4 sockets 2 switches, 1 USB, 1 HDMI, 1 network port; Brands like- legrand, northwest, Wipro and MK will only be accepted</li> <li>2) Raceway for LAN &amp; Telephone connection</li> </ol>

Annexure D CARPET FOR 5TH FLOOR	Brands – Shaw Carpets, Interface, Welspun, Milliken or equivalent brands
In all the Annexures , where specified <b>Aluminum Anodized finish.</b>	May be read as : Aluminium Anodized finish and not powder coating
Chairs in all annexures (with mesh in reference images)	<ol style="list-style-type: none"> <li>1) Chair Back is Mesh AN70 , wherever the image of the chair is represented with Mesh. Other chairs as per the specification</li> <li>2) Arm Rest – 2 Dimensional height adjustable; front and back not needed ; Seat Sliding – Not Required</li> </ol>
	<p>Design – Stowaway</p> <ol style="list-style-type: none"> <li>1)Table top PLPB 1200x1200x750H; no sharp edges. Reverse Chamfering</li> <li>2)Table legs- MS base with powder coating</li> <li>3)4 Chairs: Chairs with 40 density foam and Premium Leatherette. The chair base should be of MS base with powder coating</li> </ol> <p>The vendor can have their own design base. The Design should be so that it allows the chairs to be slotted under the table for optimum space utilization Both the designs provided for reference purpose only.</p>
Legs for Cabin Tables	Wherever specified – Aluminum Die Cast to be Read as <b>“Aluminum Die Cast/ MS with Powder Coated “</b>
All Centre Tables where specified in the Annexure	For 18 mm thickness read as “25 mm Thickness”. Rest remains unchanged.
Annexure F	“Wireless charger” deleted
Annexure V Japan Desk	<p>For BookShelf, Flyer covers and Newspaper display rack and Magazine display rack: 6ft The Material is PVPB 25 mm thickness. The design provided is for reference purpose.</p>

## **Addition in Annexure U**

### **2. Lockers for housekeeping - Steel Lockers**

Type of Steel **Lockers 18** - Locker type.

Lock type 5-lever lock ; Locking arrangement (with duplicate Key) Internal locking arrangement (for 6 and 8 locker type); Provision of Name plate/Card holders in each door  
Assembly type Screwing Installation, Free Standing Steel Locker with Pedestal,  
Pedestal fitted with 3 mm Teflon bush, Pedestal height ( $\pm 5$  mm) 125 mm, Corners Rounded  
Overall height of lockers (excluding pedestal height)  $\pm 5$  mm 1855 mm Overall width of cloth lockers 1140mm, Overall depth of lockers 480 mm, Size (W x H) of Name plate/Card holder 75 x 31 (mm); Minimum thickness of steel sheet 0.8 mm; Hinges Plain butt type made from M.S sheet of minimum 1.6 mm thick. Handle of each door made up of Electroplated mild steel Handle fixed to door by Machine screws, Coated hooks made up of Chrome plated mild steel, Hanging rod made up of Mild steel tubular pipe.



3. All other terms and conditions of the tender remain unchanged.