

Bid Corrigendum

GEM/2025/B/6126188-C3

Following terms and conditions supersede all existing "Buyer added Bid Specific Terms and conditions" given in the bid document or any previous corrigendum. Prospective bidders are advised to bid as per following Terms and Conditions:

Buyer Added Bid Specific Additional Terms and Conditions

1. OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.
2. Buyer Added text based ATC clauses
 - 1) Bidders should submit all the documents on their letterhead as per the Annexures attached to the tender.
 - 2) Price should include all taxes, supplies, transportation, installation, and other charges.
 - 3) The bidder should provide a price breakup for each item quoted in the tender document.
 - 4) Please ensure timely delivery as we require these items on an emergency basis.

Date: 29/04/2025

CORRIGENDUM /ADDENDUM - 01

-

1. It is notified to all concerned parties that with reference to our **Bid Number: GEM/2025/B/6126188** **Dated:09/04/2025** the following changes are being made w.r.t. the Tender: -

	Existing	Amended To
--	----------	------------

<p>Page # 1 2 d</p>	<p>Integrated Smart Racks should support from minimum 60kW modular UPS with Scalability up to minimum 120kW with minimum 30kW power modules. The UPS should have N+N (2 x 60kVA/kW) capacity and 15 mins of backup at 60 kW IT load on each UPS</p>	<p>Integrated Smart Racks should support from minimum 60kW modular UPS with Scalability up to minimum 120kW with minimum 20kW/30kW power modules. The UPS should have N+N (2 x 60kVA/kW) capacity and 15 mins of backup at 60kW IT load on each UPS</p>
<p>Page # 1 2.1</p>	<p>The Integrated Smart Rack solution must be CE Certified.</p>	<p>Components of Integrated smart solution are CE Certified i.e. Cooling Units, Monitoring System, PDU's, UPS System.</p>

<p>Page # 2 2.2</p>	<p>The Critical Components i.e. UPS, Inrow PAC, Rack, PDU's and monitoring should be from Same OEM.</p>	<ul style="list-style-type: none"> • The critical components—UPS, InRow PAC, Racks, PDUs, and Monitoring System—must be from the same OEM. • In the case of a multi-OEM solution, the bidder shall provide: <ul style="list-style-type: none"> • An OEM-backed integration warranty; • A single point of responsibility (SOR) for the entire system; • Documentary proof of integration testing and compatibility certificates; • Joint service/support agreements among all participating OEMs. • Proof of successful prior deployment of similar multi-OEM integrated solutions, including customer references and project details, must be submitted. • Technical white papers or certificates demonstrating validated interoperability and compatibility between components from different OEMs must be included. • A joint support and escalation matrix, signed and endorsed by all participating OEMs, must be provided, detailing coordinated service responsibilities and contact hierarchy.
<p>Page # 2 3.b</p>	<p>The unit incorporates a high efficiency DC brushless compressor with a crankcase heater, filter dryer, moisture indicating sight glass, and an electronic expansion valve.</p>	<p>The unit incorporates a high efficiency DC brushless compressor/Inverter Compressor with a crankcase heater, filter dryer, moisture indicating sight glass, and an electronic expansion valve.</p>

Page # 2 3.c	The compressor is equipped with an environment-friendly refrigerant (R410A), and a DC brushless type arrangement with variable capacity/speed operation of 30% to 100%.	The compressor is equipped with an environment-friendly refrigerant (R410A), and a DC brushless type arrangement with variable / Inverter Compressor capacity/speed operation of 30% to 100%.
Page # 2 3.g	Micro Processor should have capacity to store up to 500 historical event records	Micro Processor should have capacity to store up to 100 historical event records
Page # 5 3.10.a	Power Distribution network TT/TN	Power Distribution network TT/TN or 24V DC

2. All other terms and conditions of the GEM Bid remain unchanged. Bidders, who have already submitted their bids prior to issue of this corrigendum need to submit again.

3. Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without

specifying equivalent Indian Certification / standards.

10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

*This document shall overwrite all previous versions of Bid Specific Additional Terms and Conditions.

[This Bid is also governed by the General Terms and Conditions](#)